

## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

### Monitoring Requirements Not Met for Purcell

Our water system violated drinking water requirements. Even though this was not an emergency, as our customers, you have a right to know what happened and what we are doing to correct the situation.

*We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During the following monitoring periods, we did not complete all monitoring or testing for the following contaminants, and therefore cannot be sure of the quality of your drinking water during that time.*

<u>Type of Sample</u>	<u>Monitoring Period</u>	<u>Samples Required</u>	<u>Samples Missing</u>
CHLORINE	4/1/2018 To 4/30/2018	9	3

What should I do? There is nothing you need to do at this time.

What happened? What is being done? The chlorine level of samples taken was not noted on the missing samples. We have begun to record the chlorine level of each sample again.

We anticipate resolving the problem by this date: May 1, 2018

For more information, please contact Carla Leaghty at 405-442-8212 or

City of Purcell  
ATTN: Wastewater Treatment Plant  
230 W. Main  
Purcell, OK 73051

Date PN Distributed: \_\_\_\_\_

PWSID No. OK 2004701      County: McClain